## クリーン21長谷山 維持管理記録簿

令和 5年 7月

	1号炉				2号炉			
測定項目	炉出口温度	(減温塔出口)	CO濃度(煙突入口)	排ガス冷却設備ばい塵	炉出口温度	(減温塔出口)	CO濃度(煙突入口)	排ガス冷却設備ばい塵
管理値	850℃ 以上	200℃ 以下	30ppm 以下	除去	850℃ 以上	200℃ 以下	30ppm 以下	定 除 去
単位	°C	°C	ppm		°C	°C	ppm	
1	952	160	2	0	949	160	2	0
2	946	160	4	0	951	160	2	0
3	947	160	3	0	951	160	4	0
4	957	160	4	0	958	160	6	0
5	952	160	6	0	960	160	7	0
6	941	160	7	0	953	160	5	0
7	943	160	4	0			4	0
					953	160	4	0
8	946	160	5	0				
9	952	160	3	0				
10	946	160	5	0		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		VIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII
11	948	160	5	0				
12	948	161	5	0				
13	952	160	4	0				
14	945	160	5	0				
15	946	160	8	0				
16	949	160	4	0				
17	943	160	5	O				
18	949	161	5	0				
19	952	160	5	0				
20	947	160	5	0				
21	945	160	5	0				,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
22	954	160	4	0				
23	951	160	5	0				
23				0				
	951	160	5					
25	956	160	4	0				
26	957	160	5	0				
27	950	160	5	0				
28	950	161	4	0				
29	952	160	4	0				
30	954	160	4	0		,		
31	950	160	5	0				
月平均	949	160	5	_	954	160	4	_