

# クリーン21長谷山 維持管理記録簿

令和 7年度 11月

測定項目	1号炉					2号炉					排ガス冷却設備ばい塵除去
	炉出口温度	集じん器入口温度 (減温塔出口温度)	CO濃度(煙突入口)	排ガス冷却設備ばい塵除去 (ストップロワ)	炉出口温度	集じん器入口温度 (減温塔出口)	CO濃度(煙突入口)	排ガス冷却設備ばい塵除去			
管理値	850°C以上	200°C以下	30ppm以下		850°C以上	200°C以下	30ppm以下				
単位	°C	°C	ppm		°C	°C	ppm				
1					962	161	4		○		
2					959	161	4		○		
3					954	161	4		○		
4					959	161	4		○		
5					961	161	4		○		
6					961	161	4		○		
7					962	161	4		○		
8					959	161	5		○		
9					957	161	4		○		
10					952	161	4		○		
11					953	161	5		○		
12					955	161	5		○		
13					957	161	4		○		
14					954	161	4		○		
15					955	161	5		○		
16					959	161	4		○		
17					954	161	5		○		
18					953	161	5		○		
19					957	161	5		○		
20					953	161	5		○		
21					954	161	5		○		
22					958	161	5		○		
23					956	161	4		○		
24					952	161	4		○		
25					951	161	5		○		
26					945	161	5		○		
27					951	161	5		○		
28					952	161	5		○		
29					955	161	5		○		
30					955	161	4		○		
月平均				—	956	161	4	—			