

クリーン21長谷山 維持管理記録簿

令和 3年 4月

測定項目	1号炉				2号炉										
	炉出口温度	集じん器入口温度 (減温塔出口)	CO濃度 (煙突入口)	排ガス冷却設備ばい塵除去 (スートブロワ)	炉出口温度	集じん器入口温度 (減温塔出口)	CO濃度 (煙突入口)	排ガス冷却設備ばい塵除去 (スートブロワ)							
									管理値	850℃以上	200℃以下	30ppm以下	850℃以上	200℃以下	30ppm以下
									単位	℃	℃	ppm	℃	℃	ppm
1	982	160	6	○											
2	972	160	7	○											
3	973	160	8	○											
4	963	160	7	○	957	160	6	○							
5	971	160	8	○	961	160	9	○							
6	958	160	8	○	956	160	7	○							
7	968	160	7	○	957	160	7	○							
8	966	160	6	○	956	160	6	○							
9	965	160	6	○	958	160	5	○							
10	965	160	5	○	956	160	4	○							
11					965	160	4	○							
12					960	160	7	○							
13					954	160	7	○							
14					962	160	8	○							
15					964	160	9	○							
16					963	160	7	○							
17					962	160	8	○							
18					961	160	7	○							
19					958	160	8	○							
20					955	160	6	○							
21					964	160	4	○							
22					958	160	4	○							
23					962	160	4	○							
24					960	160	5	○							
25					957	160	4	○							
26					958	160	4	○							
27					961	160	5	○							
28					959	160	4	○							
29					958	160	5	○							
30					953	160	5	○							
月平均	968	160	7	—	959	160	6	—							