

# クリーンパーク折居 維持管理記録簿

令和 元年      10月

測定項目	1号炉				2号炉										
	炉出口温度	ろ過式集じん器入口温度	CO濃度（煙突）	排ガス冷却設備ばい塵除去（スートブロワ）	炉出口温度	ろ過式集じん器入口温度	CO濃度（煙突）	排ガス冷却設備ばい塵除去（スートブロワ）							
									管理値	800℃以上	200℃以下	30ppm以下	800℃以上	200℃以下	30ppm以下
									単位	℃	℃	ppm	℃	℃	ppm
1	937	172	9	○											
2	942	172	7	○											
3	945	171	6	○	945	184	4								
4	942	172	9	○	944	172	5	○							
5	945	172	7	○	936	172	5	○							
6	949	173	8	○	945	172	7	○							
7					945	171	3	○							
8					947	170	2	○							
9					951	169	4	○							
10					936	170	6	○							
11					941	170	4	○							
12					939	169	3	○							
13					943	170	5	○							
14					940	170	5	○							
15					940	170	7	○							
16					946	169	6	○							
17					945	169	4	○							
18					947	169	5	○							
19					944	169	5	○							
20					951	170	3	○							
21					947	169	4	○							
22					940	170	4	○							
23					938	170	5	○							
24					942	169	6	○							
25					937	169	6	○							
26					931	171	7	○							
27					940	170	6	○							
28	947	168	3	○	934	170	5	○							
29	940	167	5	○	937	171	5	○							
30	944	168	5	○	934	171	5	○							
31	948	168	5	○	932	171	5	○							
月平均	944	170	6	—	941	171	5	—							

※ 一酸化炭素濃度は、4時間平均値で管理しています。